



NOTES:

1. All flatwork shall use Class A concrete (minimum 3000 psi at 28 days) unless otherwise detailed or specified. Concrete requirements for flatwork of any other class shall be labeled on the plans and called out in the specifications.
2. No reinforcing bars will be closer than three (3") inches to edge of concrete.
3. 1/2" preformed expansion joint material shall be placed at intervals not to exceed thirty (30') feet in the curb and gutter or as directed by the engineer. Scoring joints (dummy joints) shall be placed in curb and gutters with jointing tools at intervals not to exceed five (5') feet.
4. 1" sand cushion shall be wetted and forms oiled prior to placing any concrete.

	Drawn by: rjh	Date: 8/27/12	Description <h2 style="text-align: center;">Sidewalk with 8" Side Curb</h2>
	Designed by: rjh	Job No:	
	Path: ... \Sidewalk*with*8*in*Side*curb.dgn		
	Scale: 1" = 10'	Sheet 1	