

ADDENDUM TO 2005 WATER QUALITY REPORT

Disinfectant Residuals

Year	Constituent	Highest Average	Range of Detects	MRDL	MCLG	Units	Source
2004	Chlorine disinfectant	1.21	0.59-1.81	4	0.0	ppm	disinfectant used to control microbes

Unregulated Contaminant Monitoring Rule (UCMR)

We participated in gathering data under the UCMR in order to assist EPA in determining the occurrence of possible drinking water contaminants. If any unregulated contaminants were detected, they are shown in the tables elsewhere in this report. This data may also be found on EPA's web site at <http://www.epa.gov/safewater/data/ncod.html>, or you can call the Safe Drinking Water Hotline at 1-800-426-4791.

Arsenic	MCL	Average
	50 ppb	3 ppb

Note: Effective January 23, 2006 the MCL will change to 10 ppb. There is no MCLG.

Total Organic Carbon (TOC)	High	Low	Average
	3.790	2.131	3.103

The source of TOC is "naturally occurring", and there are no health effects directly associated with it.

Source Water Assessment

TCEQ completed an assessment of your source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this consumer confidence report. For more information on source water assessments and protection efforts at our system contact Larry West, 806-378-3019.