Figure: 25 TAC §265.204(a)

1. Disinfectant Levels	Minimum	Ideal	Ideal	
Free Chlorine - pools	1.0 ppm	2.0 - 3.0 ppm		8.0 ppm
Free Chlorine - spas	2.0 ppm	3.0 - 5.0 ppm		8.0 ppm
Combined Chlorine	None	None		None
Bromine - pools	2.5 ppm	2.5 - 6.0 ppm	2.5 - 6.0 ppm	
Bromine - spas	4.5 ppm	5.5 - 7.5 ppm	5.5 - 7.5 ppm	
2. pH Levels	Minimum	Ideal		Maximum
рН	Not less than 7.0	7.4 - 7.6		7.8
3. Water Clarity	Minimum	Ideal	Maximum	
Water turbidity	Bottom and main drain shall be clearly visible at the deepest part of the pool or spa (Section 265.203(c))	Bottom and main drain shall be clearly visible at the deepest part of the pool or spa (Section 265.203(c))	Bottom and main drain shall be clearly visible at the deepest part of the pool or spa (Section 265.203(c))	
4. Spa Temperature	Minimum	Ideal	Maximum	
Temperature ° F	N/A	102° F or less	104° F (40° C)	
5. Stabilizer (cyanuric acid)	Minimum	Ideal		Maximum
Cyanuric acid	None*	10.0 - 40.0 ppm		100.0 ppm

^{*}Stabilizer shall not be used in indoor pools or spas or brominated pools or spas