


NOTES:

1. All flatwork shall use Class A (minimum 4,000 psi at 28 days) concrete unless otherwise detailed or specified. Concrete requirements for flatwork of any other class shall be labeled on the plans and called out in the specifications.
2. No reinforcing bars will be closer than three inches (3") to edge of concrete.
3. 1/2" preformed expansion joint feet in the curb and gutter or as directed by the engineer. Scoring joints (dummy joints) shall be placed in curbs and gutters with jointing tools at intervals not to exceed five (5') feet.
4. 1" sand cushion shall be wetted and forms oiled prior to placing any concrete.
5. Dowel new sidewalk into existing sidewalk.
6. Accessible Ramps shall be installed where sidewalk approaches apron. Cross Slope where sidewalk crosses apron shall not exceed 2%. See City of Amarillo ADA Ramp Details, Sidewalk Details, and Driveway and Parking Manual (Latest Edition) for more information.

| | | | | | |
|--|--------------|-----|---------|------------|---|
| <p>CITY OF AMARILLO</p>  <p>ENGINEERING DEPARTMENT</p> | Drawn by: | rjh | Date: | 11/15/2010 | <p>Description</p> <p>Restricted Parkway Alley Apron</p> |
| | Designed by: | rjh | Job No: | | |
| | Path: | | | | |
| | Scale: | nts | Sheet | 1 | |